

EPart III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	220002789
Drinking-Water System Name:	Elliot Lake Water Works
Drinking-Water System Owner:	Corporation of the City of Elliot Lake
Drinking-Water System Category:	Water Treatment Subsystem Class 2
Period being reported:	January 1 – December 31, 2006

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [<input checked="" type="checkbox"/>] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [<input checked="" type="checkbox"/>] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>The summary report will be available at City Hall, the Water Treatment Plant, and will be posted on the City's website.</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
---	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

The method of treatment at the Elliot Lake Water Plant is that of direct filtration.

Water is drawn from the lake through an intake structure located in approximately 12.2m (40ft) of water and is gravity fed through a 295m long marine pipeline to the low lift pumping station wet well. The water is then pumped to the main plant on Spine Road. At the plant it passes through a raw water flow meter and into reactor/mixing tanks. At this point Polyhydroxyl Aluminum Chloride (PAC) is added to the process to aid in the production of floc (particulate matter of sufficient size to be removed by the filters). The water is then filtered through granular media, collected in an underdrain system, and stored in a clearwell (storage reservoir) on site.

Chlorine is added to the treated water as it leaves the filters to achieve required disinfection. Fluoride is also added at this point. Fluoride does not play a role in the treatment process but rather acts as an agent in the prevention of tooth decay in young children.

Lime is added to the water as it leaves the plant to aid in the prevention of corrosion in the distribution system. Water pumped from the plant enters the distribution system where it makes its way to consumers' homes, either directly or from the standpipe storage facilities.

List all water treatment chemicals used over this reporting period

Chlorine, Polyhydroxyl Aluminum Chloride (PAC), Lime, Fluoride

Were any significant expenses incurred to?

- Install required equipment

- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

No significant expenses were incurred to either install, repair, or replace required equipment.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Aug. 31	Coliform bacteria	7	cfu/100ml	Flush/resample	Aug. 31
Dec. 13	Coliform bacteria	1	cu/100ml	resample	Dec. 14

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0 - 8	0 - >160		
Treated	52	Absent	Absent	52	0 - <2
Distribution	331	Absent	Absent - 7	121	0 - 19

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	.22 - .63 (NTU)
Chlorine	8760	0.90– 1.65 (mg/l)
Chlorine Residual Distribution System	644	0.11 – 1.38 (mg/l) as free chlorine
Fluoride (If the DWS provides fluoridation)	365	0 - .82 (mg/l)

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
C of A Feb. 13,2002	Clarifier Overflow Suspended Solids	January 13	16	mg/L
		February 3	11	mg/L
		March 3	2	mg/L
		April 7	4	mg/L
		May 12	12	mg/L
		June 22	15	mg/L
		July 12	4	mg/L
		August 25	4	mg/L
		September 8	8	mg/L
		October 6	6	mg/L
		November 24	2	mg/L
		December 20	16	mg/L

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Jan.18/06	<0.001	mg/l	no
Arsenic	Jan.18/06	<0.001	mg/l	no
Barium	Jan.18/06	0.014	mg/l	no
Boron	Jan.18/06	<0.010	mg/l	no
Cadmium	Jan.18/06	<0.0001	mg/l	no
Chromium	Jan.18/06	0.005	mg/l	no
Lead	Mar. 14/06	<0.0005	mg/l	no
Mercury	Jan.18/06	<0.0001	mg/l	no
Selenium	Jan.18/06	<0.002	mg/l	no
Sodium				
Uranium	Jan.18/06	0.0001	mg/l	no
Fluoride				
Nitrite	Quarterly	Ave. = <0.05	mg/l	no
Nitrate	Quarterly	Ave. = <0.11	mg/l	no

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Jan.18	<0.50	ug/L	no

Aldicarb	Jan.18	<5.0	ug/L	no
Aldrin + Dieldrin	Jan.18	<0.012	ug/L	no
Atrazine + N-dealkylated metabolites	Jan.18	<0.50	ug/L	no
Azinphos-methyl (Guthion)	Jan.18	<2.0	ug/L	no
Bendiocarb	Jan.18	<2.0	ug/L	no
Benzene	Jan.18	<0.10	ug/L	no
Benzo(a)pyrene	Jan.18	<0.009	ug/L	no
Bromoxynil	Jan.18	<0.50	ug/L	no
Carbaryl	Jan.18	<5.0	ug/L	no
Carbofuran	Jan.18	<5.0	ug/L	no
Carbon Tetrachloride	Jan.18	<0.10	ug/L	no
Chlordane (Total)	Jan.18	<0.012	ug/L	no
Chlorpyrifos	Jan.18	<1.0	ug/L	no
Cyanazine	Jan.18	<1.0	ug/L	no
Diazinon	Jan.18	<1.0	ug/L	no
Dicamba	Jan.18	<1.0	ug/L	no
1,2-Dichlorobenzene	Jan.18	<0.10	ug/L	no
1,4-Dichlorobenzene	Jan.18	<0.10	ug/L	no
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Jan.18	<0.024	ug/L	no
1,2-Dichloroethane	Jan.18	<0.10	ug/L	no
1,1-Dichloroethylene (vinylidene chloride)	Jan.18	<0.10	ug/L	no
Dichloromethane	Jan.18	<0.50	ug/L	no
2-4 Dichlorophenol	Jan.18	<0.50	ug/L	no
2,4-Dichlorophenoxy acetic acid (2,4-D)	Jan.18	<1.0	ug/L	no
Diclofop-methyl	Jan.18	<0.90	ug/L	no
Dimethoate	Jan.18	<2.5	ug/L	no
Dinoseb	Jan.18	<1.0	ug/L	no
Diquat	Jan.18	<7.0	ug/L	no
Diuron	Jan.18	<10.0	ug/L	no
Glyphosate	Jan.18	<10.0	ug/L	no
Heptachlor + Heptachlor Epoxide	Jan.18	<0.012	ug/L	no
Lindane (Total)	Jan.18	<0.006	ug/L	no
Malathion	Jan.18	<5.0	ug/L	no
Methoxychlor	Jan.18	<0.024	ug/L	no
Metolachlor	Jan.18	<0.50	ug/L	no
Metribuzin	Jan.18	<5.0	ug/L	no
Monochlorobenzene	Jan.18	<0.10	ug/L	no
Paraquat	Jan.18	<1.0	ug/L	no
Parathion	Jan.18	<1.0	ug/L	no
Pentachlorophenol	Jan.18	<0.50	ug/L	no
Phorate	Jan.18	<0.50	ug/L	no
Picloram	Jan.18	<5.0	ug/L	no

Polychlorinated Biphenyls(PCB)	Jan.18	<0.05	ug/L	no
Prometryne	Jan.18	<0.25	ug/L	no
Simazine	Jan.18	<1.0	ug/L	no
THM (NOTE: show latest annual average)	Jan.18	47.25	ug/L	no
Temephos	Jan.18	<10.0	ug/L	no
Terbufos	Jan.18	<0.70	ug/L	no
Tetrachloroethylene	Jan.18	<0.10	ug/L	no
2,3,4,6-Tetrachlorophenol	Jan.18	<0.50	ug/L	no
Triallate	Jan.18	<1.0	ug/L	no
Trichloroethylene	Jan.18	<0.10	ug/L	no
2,4,6-Trichlorophenol	Jan.18	<0.50	ug/L	no
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Jan.18	<1.0	ug/L	no
Trifluralin	Jan.18	<1.0	ug/L	no
Vinyl Chloride	Jan.18	<0.20	ug/L	no

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
THM	50.5	Mg/l	July 10
THM	55.6	Mg/l	October 30

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)